



TOWNSHIP OF UPPER PROVIDENCE OFFICE OF THE FIRE MARSHAL

REQUIREMENTS FOR FIRE ALARM INSTALLATION AND SERVICE PERSONNEL

In accordance with Section 10.5.2 of NFPA 72, 2013 Edition (National Fire Alarm and Signaling Code), installation personnel shall be qualified or shall be supervised by persons who are qualified in the installation, inspection and testing of fire alarm systems. Qualified personnel shall include, but not be limited to, one of more of the following:

- (1) Personnel who are factory trained and certified for fire alarm installation of the specific type and brand of system being installed.
- (2) Personnel who are certified by a nationally recognized fire alarm certification organization (i.e. NICET) acceptable to the Upper Providence Township Fire Marshal's Office.

In accordance with Section 10.5.3.3 of NFPA 72, 2013 Edition (National Fire Alarm Code), service personnel shall be qualified and experienced in the inspection, testing and maintenance of fire alarm systems. Qualified personnel shall include, but not be limited to, one of more of the following:

- (1) Personnel who are factory trained and certified for fire alarm service of the specific type and brand of system being installed.
- (2) Personnel who are certified by a nationally recognized fire alarm certification organization (i.e. NICET) acceptable to the Upper Providence Township Fire Marshal's Office.
- (3) Personnel who are employed and qualified by an organization listed by a nationally recognized testing laboratory for the servicing of fire alarm systems (Underwriters Laboratories or Factory Mutual)

EVIDENCE OF QUALIFICATIONS OR CERTIFICATIONS SHALL BE PROVIDED UPON REQUEST BY THE FIRE MARSHAL'S OFFICE

AFFIDAVIT OF TRAINING AND EXPERIENCE

I, _____ represent that I am qualified to install and/or service fire alarm systems because I am:

- A factory trained and certified individual
- Fire Alarm certified by a nationally recognized fire alarm certification organization (i.e. NICET)
- An employed and qualified employee of an organization listed by a national testing laboratory for the servicing of fire alarm systems (Underwriters Laboratories or Factory Mutual)

Please Attach Supporting Documentation

Signature: _____ Date: _____

Company: _____ Phone: _____ Fax: _____

Address: _____